



Kip Peters

Hudson Public Utilities Director

Mailing: 505 Third St. Hudson, WI. 54016

Offices: 1201 Livingstone Rd. Hudson, WI. 54016

Phone: (715) 386-4765, ext. 115

kpeters@hudsonwi.gov

www.hudsonpublicutilities.com

I'm contacting you to comply with DNR code requirement NR.210.23(4)(f) which states; Such public notification shall occur promptly following any overflow event using the most effective and efficient communications available in the community. At minimum, a daily newspaper of general circulation in the county(s) and municipality whose waters may be affected by the overflow shall be notified by written or electronic communication. Publication of this notice is solely at the discretion of the newspaper.

On May 4, 2021 from approximately 8:00PM to 12:00AM May 5, 2021, Hudson Utilities experienced a sanitary sewer overflow near the Wastewater Treatment Plant at 329 Front St. Approximately 200,000 gallons of sewage was overflowed through manholes located in the Hudson Marina and another approximate 200,000 gallons was diverted to a temporary holding area that was dug into the soil in front of the Treatment Plant. NO HEALTH RISKS were determined.

The overflow occurred due to a broken power line supplying power to the pretreatment building.

Any questions or concerns, please contact me.

Thanks,

Kip Peters
Utility Director